

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Conant Elementary School

Date: 8/4/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 68

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) N/A

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 68

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (www.anytownschools.k12.us). For more information about water quality in our schools, please contact (John Doe) at (Anytown School District, 555-2233). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: () Posting in Common Areas of School Buildings; () E-mail or Letter to Parents, Teachers and Staff; () Posting on Website; () Newsletter.

Signed and Certified

Name and Title



**Bloomfield Hills Schools
Drinking Water Analysis
Project Number: AE170159**

Conant Elementary School
Date of Sampling: 5/3/17
Sampler: Amanda Peterson

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Conant ES-01	Kitchen, 3-Compartment Sink, Left Faucet	KS	6:04 AM	15	ND ³	Y	First Draw
Conant ES-02	Kitchen, 3-Compartment Sink, Right Faucet	KS	6:05 AM	15	1	Y	First Draw
Conant ES-03	In Hallway, to the Left of Principals Office, Water Cooler	WC	6:07 AM	15	ND	Y	First Draw
Conant ES-04	In Hallway, to the Left of Principals Office, Bottle Fill	BT	6:08 AM	15	ND	Y	First Draw
Conant ES-05	In Hallway to the Right of the Main Office	B	6:10 AM	15	ND	N	First Draw
Conant ES-06	Room 104, Bubblers	B	6:12 AM	15	1	Y	First Draw
Conant ES-07	Room 108, Bubblers	B	6:20 AM	15	2	N	First Draw
Conant ES-08	Room 106, Bubblers	B	6:24 AM	15	ND	Y	First Draw
Conant ES-09	Room 105, Bubblers	B	6:27 AM	15	3	N	First Draw
Conant ES-10	Staff Lounge	KS	6:34 AM	15	ND	Y	First Draw
Conant ES-11	Room 301, Bubblers	B	6:37 AM	15	ND	Y	First Draw
Conant ES-12	Room 302, Bubblers	B	6:39 AM	15	ND	N	First Draw
Conant ES-13	In Hallway, to the Right of Room 305	B	6:41 AM	15	1	N	First Draw
Conant ES-14	Room 305, Bubblers	B	6:43 AM	15	ND	Y	First Draw
Conant ES-15	Room 304, Bubblers	B	6:46 AM	15	ND	N	First Draw

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Bloomfield Hills Schools
Drinking Water Analysis
Project Number: AE170536**

Conant Elementary School

Date of Sampling: July 7, 2017

Sampler: Lindsey Eveleth

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Conant ES-16	Preschool Room 1, Left Bubblers	B	11:55 AM	15	ND ³	N	First Draw
Conant ES-17	Preschool Room 1, Right Bubblers	B	11:57 AM	15	ND	N	First Draw
Conant ES-18	Preschool Room 1, Left Faucet	CF	11:57 AM	15	ND	Y	First Draw
Conant ES-19	Preschool Room 2, Bubblers	B	12:13 PM	15	ND	N	First Draw
Conant ES-20	Preschool Room 3, Bubblers	B	12:14 PM	15	ND	N	First Draw
Conant ES-21	Preschool Room 5, Bubblers	B	12:17 PM	15	1	N	First Draw
Conant ES-22	Preschool Staff Lounge, Front Faucet, Right of Entryway	KS	12:23 PM	15	ND	Y	First Draw
Conant ES-23	Preschool Staff Lounge, Back Faucet, Right of Refrigerator	KS	12:25 PM	15	1	N	First Draw
Conant ES-24	Preschool, in Hallway, Between Rooms 4 and 5, Bottle Fill	BT	12:27 PM	15	ND	N	First Draw
Conant ES-25	Right Water Cooler, Preschool Hallway, Between Rooms 4 and 5	WC	12:29 PM	15	ND	N	First Draw
Conant ES-26	Left Water Cooler, Preschool Hallway, Between Rooms 4 and 5	WC	12:30 PM	15	ND	N	First Draw
Conant ES-27	Preschool Room 4, Left Bubblers	B	12:45 PM	15	ND	N	First Draw
Conant ES-28	Preschool Room 4, Right Bubblers	B	12:46 PM	15	1	N	First Draw
Conant ES-29	Preschool Room 4, Right Faucet	CF	12:46 PM	15	2	Y	First Draw
Conant ES-30	Room 404 (Visual Arts), Bubblers	B	12:49 PM	15	ND	N	First Draw
Conant ES-31	in Kitchen, Faucet to Left of Boiler Room Entry	KS	12:55 PM	15	3	Y	First Draw
Conant ES-32	Room 109, Faucet	CF	1:03 PM	15	1	Y	First Draw
Conant ES-33	Room 109, Bubblers	B	1:05 PM	15	1	N	First Draw
Conant ES-34	Room 102, Bubblers	B	1:20 PM	15	8	N	First Draw
Conant ES-35	Room 102, Faucet	CF	1:20 PM	15	4	Y	First Draw
Conant ES-36	Room 101, Bubblers	B	1:25 PM	15	6	N	First Draw
Conant ES-37	Room 101, Faucet	CF	1:26 PM	15	7	Y	First Draw
Conant ES-38	in Gymnasium, Bubblers	B	1:30 PM	15	ND	N	First Draw
Conant ES-39	Room 103, Bubblers	B	1:45 PM	15	2	N	First Draw
Conant ES-40	Room 103, Faucet	CF	1:46 PM	15	6	Y	First Draw
Conant ES-41	Room 108, Faucet	CF	1:50 PM	15	3	Y	First Draw
Conant ES-42	Room 104, Faucet	CF	1:51 PM	15	3	N	First Draw
Conant ES-43	Room 107, Bubblers	B	1:55 PM	15	4	N	First Draw
Conant ES-44	Room 107, Faucet	CF	1:56 PM	15	9	N	First Draw
Conant ES-45	Room 105, Faucet	CF	1:59 PM	15	2	Y	First Draw
Conant ES-46	Room 106, Faucet	CF	2:03 PM	15	4	Y	First Draw
Conant ES-47	In Media Center, Teacher Learning Center	CF	2:05 AM	15	9	Y	First Draw
Conant ES-48	Room 201, Bubblers	B	2:07 PM	15	1	N	First Draw
Conant ES-49	Room 201, Faucet	CF	2:07 PM	15	2	Y	First Draw

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Bloomfield Hills Schools
Drinking Water Analysis
Project Number: AE170536**

Conant Elementary School							
Date of Sampling: July 7, 2017							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Conant ES-50	Room 202, Bubblers	B	2:09 PM	15	4	N	First Draw
Conant ES-51	Room 202, Faucet	CF	2:09 PM	15	8	Y	First Draw
Conant ES-52	Room 206, Bubblers	B	2:15 PM	15	2	N	First Draw
Conant ES-53	Room 206, Faucet	CF	2:17 PM	15	5	Y	First Draw
Conant ES-54	In Hallway, Between Rooms 206 and 205	B	2:25 PM	15	4	N	First Draw
Conant ES-55	Room 205, Bubblers	B	2:26 PM	15	2	N	First Draw
Conant ES-56	Room 205, Faucet	CF	2:27 PM	15	3	Y	First Draw
Conant ES-57	Room 203, Bubblers	B	2:33 PM	15	1	N	First Draw
Conant ES-58	Room 203, Faucet	CF	2:33 PM	15	1	Y	First Draw
Conant ES-59	Room 204, Bubblers	B	2:36 PM	15	3	N	First Draw
Conant ES-60	Room 204, Faucet	CF	2:37 PM	15	9	Y	First Draw
Conant ES-61	Room 301, Faucet	CF	2:40 PM	15	1	Y	First Draw
Conant ES-62	Room 302, Faucet	CF	2:42 PM	15	4	Y	First Draw
Conant ES-63	Room 306, Bubblers	B	2:47 PM	15	6	N	First Draw
Conant ES-64	Room 306, Faucet	CF	2:48 PM	15	ND	Y	First Draw
Conant ES-65	Room 305, Faucet	CF	3:00 PM	15	9	Y	First Draw
Conant ES-66	Room 303, Bubblers	B	3:03 PM	15	ND	N	First Draw
Conant ES-67	Room 303, Faucet	CF	3:05 AM	15	4	Y	First Draw
Conant ES-68	Room 304, Faucet	CF	3:07 AM	15	4	Y	First Draw

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested