

**Public Notification to Parents, Teachers, and Staff  
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Eastover Elementary School

Date: 8/4/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 60

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) N/A

**Testing Results:**

Number of Lead Tests Completed: (zero if not applicable) 57

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: \_\_\_\_\_

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<http://www.bloomfield.org>). For more information about water quality in our schools, please contact (Physical Plant Services) at (248-341-5490). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ ([www.michigan.gov/drinkingwater](http://www.michigan.gov/drinkingwater)).

This Public Notification is being distributed through the following means: ( ) Posting in Common Areas of School Buildings; ( ) E-mail or Letter to Parents, Teachers and Staff; ( ) Posting on Website; ( ) Newsletter.

Signed and Certified

\_\_\_\_\_  
Name and Title



**Bloomfield Hills Schools  
Drinking Water Analysis  
Project Number: AE170159**

| <b>Eastover Elementary School</b>     |  |                   |                |                                      |                 |                     |            |
|---------------------------------------|--|-------------------|----------------|--------------------------------------|-----------------|---------------------|------------|
| <b>Date of Sampling: May 16, 2017</b> |  |                   |                |                                      |                 |                     |            |
| <b>Sampler: Steven Brewer</b>         |  |                   |                |                                      |                 |                     |            |
| Sample #                              | Location                                 | Type <sup>1</sup> | Time Collected | EPA Action Level (ug/L) <sup>2</sup> | Results (ug/L)  | Aerator Present Y/N | Notes      |
| EO-01                                 | Bottle Fill in Front Entry               | WC                | 5:55 AM        | 15                                   | ND <sup>3</sup> | N/A                 | First Draw |
| EO-02                                 | Water Cooler at Front Entry              | WC                | 5:57 AM        | 15                                   | ND              | N/A                 | First Draw |
| EO-03                                 | Sink in Clinic                           | CF                | 5:59 AM        | 15                                   | ND              | Y                   | First Draw |
| EO-04                                 | Room 222, Bubblers                       | B                 | 6:02 AM        | 15                                   | ND              | N/A                 | First Draw |
| EO-05                                 | Room 222, Faucet                         | CF                | 6:04 AM        | 15                                   | 1               | Y                   | First Draw |
| EO-06                                 | East Kindergarten, Bubblers              | B                 | 6:07 AM        | 15                                   | ND              | N/A                 | First Draw |
| EO-07                                 | East Kindergarten, Faucet                | CF                | 6:08 AM        | 15                                   | ND              | Y                   | First Draw |
| EO-08                                 | Room 302, Bubblers                       | B                 | 6:11 AM        | 15                                   | ND              | N/A                 | First Draw |
| EO-09                                 | Room 302, Faucet                         | CF                | 6:13 AM        | 15                                   | ND              | Y                   | First Draw |
| EO-10                                 | Room 305, Bubblers                       | B                 | 6:16 AM        | 15                                   | ND              | N/A                 | First Draw |
| EO-11                                 | Room 305, Faucet                         | CF                | 6:18 AM        | 15                                   | ND              | Y                   | First Draw |
| EO-12                                 | Water Cooler, Right of East Kindergarten | WC                | 6:19 AM        | 15                                   | ND              | N/A                 | First Draw |
| EO-13                                 | Room 404, Bubblers                       | B                 | 6:25 AM        | 15                                   | 1               | N/A                 | First Draw |
| EO-14                                 | Room 404, Faucet                         | CF                | 6:27 AM        | 15                                   | ND              | Y                   | First Draw |
| EO-15                                 | Water Cooler, Left of Room 202           | WC                | 6:31 AM        | 15                                   | ND              | N/A                 | First Draw |

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Bloomfield Hills Schools  
Drinking Water Analysis  
Project Number: AE170536**

**Eastover Elementary School**

**Date of Sampling: July 11th, 2017**

**Sampler: Andrew Kelly**

| Sample # | Location                                   | Type <sup>1</sup> | Time Collected | EPA Action Level (ug/L) <sup>2</sup> | Results (ug/L)  | Aerator Present Y/N | Notes                                   |
|----------|--|-------------------|----------------|--------------------------------------|-----------------|---------------------|---|
| EO-16    | West Kindergarten Faucet                   | CF                | 12:30 PM       | 15                                   | 2               | Y                   | First Draw                              |
| EO-17    | West Kindergarten Bubbler                  | B                 | 12:31 PM       | 15                                   | ND <sup>3</sup> | N/A                 | First Draw                              |
| EO-18    | Water Cooler in Art and Music Wing Hallway | WC                | 3:00 PM        | 15                                   | ND              | N                   | First Draw                              |
| EO-19    | Room 301 Faucet                            | CF                | 12:42 PM       | 15                                   | 1               | Y                   | First Draw                              |
| EO-20    | Room 301 Bubbler                           | B                 | 12:43 PM       | 15                                   | 10              | N/A                 | First Draw                              |
| EO-21    | Room 304 Faucet                            | CF                | 12:44 PM       | 15                                   | 12              | Y                   | First Draw                              |
| EO-22    | Room 304 Bubbler                           | B                 | 12:45 PM       | 15                                   | 2               | N/A                 | First Draw                              |
| EO-23    | Room 306 Faucet                            | CF                | 12:46 PM       | 15                                   | 14              | Y                   | First Draw                              |
| EO-24    | Room 306 Bubbler                           | B                 | 12:47 PM       | 15                                   | ND              | N/A                 | First Draw                              |
| EO-25    | Room 303 Faucet                            | CF                | 12:52 PM       | 15                                   | 2               | Y                   | First Draw                              |
| EO-26    | Room 303 Bubbler                           | B                 | 12:53 PM       | 15                                   | ND              | N/A                 | First Draw                              |
| EO-27    | Room 101 Faucet                            | CF                | 1:10 PM        | 15                                   | 1               | Y                   | First Draw                              |
| EO-28    | Room 101 Bubbler                           | B                 | 1:11 PM        | 15                                   | ND              | N/A                 | First Draw                              |
| EO-29    | Room 102 Faucet                            | CF                | 1:12 PM        | 15                                   | 6               | Y                   | First Draw                              |
| EO-30    | Room 102 Bubbler                           | B                 | 1:13 PM        | 15                                   | 1               | N/A                 | First Draw                              |
| EO-31    | Room 103 Faucet                            | CF                | 1:14 PM        | 15                                   | 3               | Y                   | First Draw                              |
| EO-32    | Room 103 Bubbler                           | B                 | 1:15 PM        | 15                                   | 3               | N/A                 | First Draw                              |
| EO-33    | Room 104 Faucet                            | CF                | 1:16 PM        | 15                                   | 1               | Y                   | First Draw                              |
| EO-34    | Room 104 Bubbler                           | B                 | 1:17 PM        | 15                                   | ND              | N/A                 | First Draw                              |
| EO-35    | Room 105 Faucet                            | CF                | 1:18 PM        | 15                                   | 3               | Y                   | First Draw, Faucet Leaking into Sink    |
| EO-36    | Room 105 Bubbler                           | B                 | 1:19 PM        | 15                                   | 5               | N/A                 | First Draw, Faucet Leaking into Bubbler |
| EO-37    | Room 106 Faucet                            | CF                | 1:20 PM        | 15                                   | 1               | Y                   | First Draw                              |
| EO-38    | Room 106 Bubbler                           | B                 | 1:21 PM        | 15                                   | ND              | N/A                 | First Draw                              |
| EO-39    | Room 402 Faucet                            | CF                | 1:35 PM        | 15                                   | 7               | Y                   | First Draw                              |
| EO-40    | Room 402 Bubbler                           | B                 | 1:36 PM        | 15                                   | 2               | N/A                 | First Draw                              |
| EO-41    | Room 403 Faucet                            | CF                | 1:37 PM        | 15                                   | 2               | Y                   | First Draw                              |
| EO-42    | Room 403 Bubbler                           | B                 | 1:38 PM        | 15                                   | 1               | N/A                 | First Draw                              |
| EO-43    | Room 405 Faucet                            | CF                | 1:47 PM        | 15                                   | ND              | Y                   | First Draw                              |
| EO-44    | Room 407 Faucet                            | CF                | 1:57 PM        | 15                                   | ND              | Y                   | First Draw                              |
| EO-45    | Room 407 Bubbler                           | B                 | 1:58 PM        | 15                                   | 4               | N/A                 | First Draw                              |
| EO-46    | Room 408 Faucet                            | CF                | 1:59 PM        | 15                                   | 5               | Y                   | First Draw                              |
| EO-47    | Room 408 Bubbler                           | B                 | 2:00 PM        | 15                                   | 4               | N/A                 | First Draw                              |
| EO-48    | Room 206 Faucet                            | CF                | 2:15 PM        | 15                                   | 4               | Y                   | First Draw                              |
| EO-49    | Room 206 Bubbler                           | B                 | 2:16 PM        | 15                                   | 3               | N/A                 | First Draw                              |
| EO-50    | Room 204 Faucet                            | CF                | 2:17 PM        | 15                                   | 2               | Y                   | First Draw                              |
| EO-51    | Room 204 Bubbler                           | B                 | 2:18 PM        | 15                                   | 3               | N/A                 | First Draw                              |
| EO-52    | Room 202 Faucet                            | CF                | 2:19 PM        | 15                                   | 1               | Y                   | First Draw                              |
| EO-53    | Room 202 Bubbler                           | B                 | 2:20 PM        | 15                                   | 1               | N/A                 | First Draw                              |
| EO-54    | Room 203 Faucet                            | CF                | 2:21 PM        | 15                                   | 2               | Y                   | First Draw                              |
| EO-55    | Room 203 Bubbler                           | B                 | 2:22 PM        | 15                                   | ND              | N/A                 | First Draw                              |
| EO-56    | Room 205 Faucet                            | CF                | 2:23 PM        | 15                                   | 1               | Y                   | First Draw                              |

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Bloomfield Hills Schools**  
**Drinking Water Analysis**  
**Project Number: AE170536**

| Sample # | Location         | Type <sup>1</sup> | Time Collected | EPA Action Level (ug/L) <sup>2</sup> | Results (ug/L) | Aerator Present Y/N | Notes   |
|----------|------------------|-------------------|----------------|--------------------------------------|----------------|---------------------|---|
| EO-57    | Room 205 Bubbler | B                 | 2:24 AM        | 15                                   | ND             | N/A                 | First Draw  |
|          | Room 405 Bubbler | B                 |                |                                      |                |                     | Not Sampled Due to Low Flow                               |
|          | Room 406 Faucet  | CF                |                |                                      |                |                     | Not Sampled Due to Furniture Storage, Sink Not Accessible |
|          | Room 406 Bubbler | B                 |                |                                      |                |                     | Not Sampled Due to Furniture Storage, Sink Not Accessible |

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND= Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested